

## NOTES

- Foundations to be min. 675mm below ground level unless otherwise specified.
- Foundations to be 300mm deep x 1000mm wide unless otherwise specified.
- Concrete to be grade35N.
- Provide 50mm lean mix blinding (10N/mm) under foundations.
- Reinforced with 5no. 12mm Ø MS bars to run full length with 12mm Ø cross bars at 900mm max. c/c tied with annealed steel wire.
- All steelwork to have min. 75mm cover.
- Foundations to internal walls to be as above but 800mm wide & 4 rows of reinforcement.
- All setting-out dimensions to be confirmed on site.

